

**SYSTEMATIC SERVICING (EQUIP) LTD
RISK ASSESSMENT RECORD**

RA 8
Project No:

SITE LOCATION:	COMPANY NAME:
OPERATIONS COVERED BY THIS ASSESSMENT: Electricity	

REF.	Key hazards associated with the above task/activity	3	2	1	5	4	3	2	1	Likelihood x Severity
		Probable	Occasional	Remote	Catastrophic	Critical	Serious	Marginal	Negligible	
1	Burn to operator		X				X			6
2	Electrical Shock		X			X				8
3	Fire		X					X		4
4										
5										
6										
7										
8										
9										
10										

Risk Assessment scale: 10+ High Risk 5-9 Medium Risk 1-4 Low Risk

PERSONS AFFECTED					
Operatives	x	Members of Public	x	Site Visitors	x
Other Workers	x	Managers	x	Young Persons	x
Others					

PPE REQUIREMENTS					
Harness & Lanyard		Hi-Viz Clothing	x	Respiratory Protection	
Hearing Protection		Eye Protection		Head Protection	
Gloves		Boots	x	Overalls	x

EXISTING CONTROL MEASURES
Information/Instruction/Training
All operatives to be made aware of the risks and the hazards associated with working with electricity
Any work will only be carried out by competent employee's
Lock off procedure to be implemented before any work is carried out

CONTROL MEASURES CONTINUED**RA 8****Information/Instruction/Training****Additional Controls**

Customers Isolator to machine will also be locked off before any work is carried out
Men at work signs will be situated at the isolators
Adequate supervision will be maintained at all times
All electrical work will be carried out under dry conditions

Comments**Residual Risk Rating**

Considering the above control measures

MEDIUM**Assessment Prepared By:****Name:****signature:****Date:**

This risk assessment should be read in conjunction with all relevant method statements, safe systems of work and associated risk assessments as detailed on the Risk Assessment Briefing record