

**SYSTEMATIC SERVICING (EQUIP) LTD
RISK ASSESSMENT RECORD**

RA 6

Project
No:

SITE LOCATION: _____ **COMPANY NAME:** _____
OPERATIONS COVERED BY THIS ASSESSMENT: Use of electrical hand tools

REF.	Key hazards associated with the above task/activity	3	2	1	5	4	3	2	1	Likelihood x Severity
		Probable	Occasional	Remote	Catastrophic	Critical	Serious	Marginal	Negligible	
1	Electrocution			X		X				4
2	Flying particles		X			X				8
3	Noise level		X				X			6
4	Trailing leads		X			X				8
5										
6										
7										
8										
9										
10										
Risk Assessment scale		10+ High Risk		5-9 Medium Risk			1-4 Low Risk			

PERSONS AFFECTED					
Operatives	x	Members of Public	x	Site Visitors	x
Other Workers	x	Managers	x	Young Persons	x
Others		SYS personnel	x		

PPE REQUIREMENTS					
Harness & Lanyard		Hi-Viz Clothing	x	Respiratory Protection	
Hearing Protection	x	Eye Protection	x	Head Protection	
Gloves	x	Boots	x	Overalls	x

EXISTING CONTROL MEASURES
Information/Instruction/Training
Manual handling training All operatives to be trained in the use of electrical hand tools All operatives to be made aware of the risks of using electrical hand tools All tools are PAT tested All tools to be 110V wherever possible

CONTROL MEASURES CONTINUED**RA 6****Information/Instruction/Training**

Training promoted and on going

Additional Controls

Equipment to be visually inspected before use
Trailing cables to be kept to minimum wherever possible identify to everyone
Cordon off area wherever applicable

Comments**Residual Risk Rating**

Considering the above control measures

MEDIUM**Assessment Prepared By:****Name:****signature:****Date:**

This risk assessment should be read in conjunction with all relevant method statements, safe systems of work and associated risk assessments as detailed on the Risk Assessment Briefing record